

**ENVIRONMENTAL AFFAIRS ENFORCEMENT REPORT  
BOARD OF HEALTH AND ENVIRONMENTAL CONTROL  
November 8, 2016**

**BUREAU OF LAND AND WASTE MANAGEMENT**

Underground Storage Tank Enforcement

- 1)     Order Type and Number:                     Consent Order 16-0097-UST  
       Order Date:                                 September 30, 2016  
       Individual/Entity:                         **BillyBob's Marinas, Inc.**  
       Facility:                                     Hilton Head Harbor RV Resort &  
   Marina  
       Location:                                     43-A Jenkins Road  
   Hilton Head Island, SC 29926  
       Mailing Address:                             P.O. Box 21585  
   Hilton Head Island, SC 29925  
       County:   Beaufort  
       \*Previous Orders:                             None  
       Permit/ID Number:                         00977  
       Violations Cited:                         State     Underground     Petroleum  
   Environmental Response Bank Act of 1988 (SUPERB Act) (Supp. 2014) and the  
   South Carolina Underground Storage Tank Control Regulation 61-  
   92.280.20(c)(1)(ii) (2012).

Summary: BillyBob's Marinas, Inc. (Individual/Entity) owns and operates underground storage tanks (USTs) in Beaufort County, South Carolina. An inspection conducted on May 3, 2016. The Individual/Entity has violated the South Carolina Underground Storage Tank Control Regulations as follows: failed to equip an underground storage tank system with overfill protection.

Action: The Individual/Entity is required to: pay a civil penalty in the amount of two thousand dollars **(\$2,000.00)**. All violations were corrected prior to the issuance of the Order.

- 2)     Order Type and Number:                     Consent Order 16-0129-UST  
       Order Date:                                 September 1, 2016  
       Individual/Entity:                         **Sokpun Flores**  
       Facility:                                     Ganesh Food Mart  
       Location:                                     32 Savannah Highway  
   Burton, SC  
       Mailing Address:                             7641 Lumbis Ave., Apt. 104

Anchorage, Alaska 99518-3162  
County: Beaufort  
Previous Orders: 15-0413-UST (\$600.00)  
Permit/ID Number: 00994  
Violations Cited: The State Underground Petroleum Environmental Response Bank Act of 1988 (SUPERB Act), S.C. code Ann. § 44-2-10 *et seq.* (2002 and Supp. 2014); and South Carolina Underground Storage Tank Control Regulation, 7 S.C. Code Ann. Regs. 61-92.280.20(e), 61-92.280.30(a), 61-92.280.31(c), 61-92.280.34(c), 61-92.280.40(a), 61-92.280.41(b)(1)(ii), 61-92.280.43(h), 61-92.280.44(a), and 61-92.280.52 (Supp 2012).

Summary: Sokpun Flores (Individual/Entity) owns and operates underground storage tanks (USTs) located in Beaufort, South Carolina. On April 18, 2016, the Department conducted a routine inspection and issued a Notice of Alleged Violation because shear valves in dispensers 1/2 and 3/4 were not properly installed; the regular unleaded spill bucket was cracked; there was no rectifier log available at the time of the inspection; there were no Statistical Inventory Reconciliation (SIR)/release detection records available at the time of the inspection; and, there was no line leak detector test results available at the time of the inspection. The Individual/Entity has violated the South Carolina Underground Storage Tank Control Regulation as follows: failed to install tanks and piping in accordance with manufacturer's instructions; failed to ensure that releases due to spilling or overfilling do not occur; failed to inspect the impressed current system every sixty (60) days; failed to provide records to the Department upon request; failed to provide adequate release detection methods for an UST system; failed to conduct an annual line tightness test on pressurized line or have monthly monitoring; failed to conduct proper release detection using SIR; failed to conduct annual test of automatic line leak detectors; and failure to investigate or confirm a suspected release within a reasonable time.

Action: The Individual/Entity is required to: submit proof that the shear valves in dispensers 1/2 and ¾ are properly installed; submit proof that the regular unleaded spill bucket has been repaired/replaced and site check results; submit the most current month's reading on the rectifier; submit line leak detector function check results for regular unleaded/premium lines; submit twelve (12) months of SIR records or tank tightness and line tightness test results for all USTs; and, pay a civil penalty in the amount of three thousand, three hundred forty-two dollars **(\$3,342.00)**.

3) Order Type and Number: Consent Order 16-0077-UST  
Order Date: September 1, 2016  
Individual/Entity: **Anjud 1, LLC**  
Facility: Anjud 1, LLC  
Location: 430 Parris Island Gateway  
Beaufort, SC 29906  
Mailing Address: Same

County: Beaufort  
Previous Orders: None  
Permit/ID Number: 01020  
Violations Cited: State Underground Petroleum  
Environmental Response Bank Act of 1988 (SUPERB Act) (2002 and Supp.  
2014), and South Carolina Underground Storage Tank Control Regulation  
R.61-92.280.20(c)(1)(ii) (Supp 2012).

Summary: Anjud 1, LLC (Individual/Entity) owns and operates underground storage tanks (USTs) located in Beaufort, South Carolina. On April 5, 2016, the Department conducted an inspection and issued a Notice of Alleged Violation because there was no ball float vent valve on the Premium UST at the time of the inspection. The Individual/Entity has violated the South Carolina Underground Storage Tank Regulation as follows: failed to maintain adequate overfill prevention.

Action: The Individual/Entity is required to: pay a civil penalty in the amount of one thousand dollars (**\$1,000.00**). All violations were corrected prior to the issuance of the Order.

4) Order Type and Number: Consent Order 16-0082-UST  
Order Date: September 1, 2016  
Individual/Entity: **Lucky Strike Investments, Inc.**  
Facility: Corner Stop 19  
Location: 1215 Greenwood Road  
Laurens, SC 29360-0881  
Mailing Address: 401 Black Oak Court  
Spartanburg, SC 29306  
County: Laurens  
Previous Orders: None  
Permit/ID Number: 05667  
Violations Cited: The State Underground Petroleum  
Environmental Response Bank Act of 1988 (SUPERB Act), S.C. code Ann. § 44-  
2-10 *et seq.* (2002 and Supp. 2014) and Section 44-2-60(A).

Summary: Lucky Strike Investments, Inc. (Individual/Entity) owns underground storage tanks (USTs) located in Laurens, South Carolina. On March 8, 2016, the Department conducted an inspection at the facility and issued a Notice of Alleged Violation for not maintaining appropriate release detection on a temporarily closed UST, in that there was more than one (1) inch of residue in the Kerosene UST that had been in extended out of use status since 2012. The Individual/Entity has violated the South Carolina Underground Storage Tank Control Regulation as follows: failed to continue release detection for a temporarily closed UST that has not been emptied to less than one inch of residue.

Action: The Individual/Entity is required to: submit proof that the UST has been emptied to less than one (1) inch of residue; and, pay a civil penalty in the

amount of five hundred dollars (**\$500.00**).

- 5)      Order Type and Number:                      Consent Order 16-0210-UST  
         Order Date:    September 8, 2016  
         Individual/Entity:                                      **TA Operating, LLC**  
         Facility:    Travel Centers of America 262  
         Location:    7400 Wilson Boulevard  
            Columbia, South Carolina  
         Mailing Address:    24601 Center Ridge Road  
            Westlake, Ohio 44145  
  
         County:    Richland  
         Previous Orders:    None  
         Permit/ID Number:    09732  
         Violations Cited:    The State Underground Petroleum  
            Environmental Response Bank Act of 1988 (SUPERB Act), S.C. code Ann. § 44-  
            2-10 *et seq.* (2002 and Supp. 2014); and South Carolina Underground Storage  
            Tank Control Regulation, 7 S.C. Code Ann. Regs. 61-92.280.41(b)(1)(i) (Supp  
            2012).

Summary: TA Operating, LLC (Individual/Entity) owns and operates underground storage tanks (USTs) located in Columbia, South Carolina. On July 19, 2016, the Department conducted a routine inspection and issued a Notice of Alleged Violation because there was no automatic line leak detector present on the diesel line at the time of the inspection. The Individual/Entity has violated the South Carolina Underground Storage Tank Control Regulation as follows: failed to equip a pressurized line with an automatic line leak detector. The automatic line leak detector was installed on the premium line and tested on July 29, 2016.

Action: The Individual/Entity is required to: pay a civil penalty in the amount of one thousand dollars (**\$1,000.00**).

- 6)      Order Type and Number:                      Consent Order 16-0191-UST  
         Order Date:    September 1, 2016  
         Individual/Entity:    **Manish S. Patel**  
         Facility:    EZ Stop 4  
         Location:    529 East Main Street  
            Ridgeland, South Carolina  
         Mailing Address:    2004 Gunpowder Court  
            Summerville, SC 29485-8871  
  
         County:    Jasper  
         Previous Orders:    None  
         Permit/ID Number:    12224  
         Violations Cited:    The State Underground Petroleum  
            Environmental Response Bank Act of 1988 (SUPERB Act), S.C. code Ann. § 44-  
            2-10 *et seq.* (2002 and Supp. 2014); and South Carolina Underground Storage

Tank Control Regulation, 7 S.C. Code Ann. Regs. 61-92.280.41(b)(1)(i) (Supp 2012).

Summary: Manish S. Patel (Individual/Entity) owns and operates underground storage tanks (USTs) located in Ridgeland, South Carolina. On July 12, 2016, the Department conducted a routine inspection and issued a Notice of Alleged Violation because there was no automatic line leak detector present on the premium line at the time of the inspection. The Individual/Entity has violated the South Carolina Underground Storage Tank Control Regulation as follows: failed to equip a pressurized line with an automatic line leak detector. The automatic line leak detector was installed on the premium line and tested on July 28, 2016.

Action: The Individual/Entity is required to: pay a civil penalty in the amount of one thousand dollars (**\$1,000.00**).

7) Order Type and Number: Consent Order 16-0162-UST  
Order Date: September 30, 2016  
Individual/Entity: **City of Isle of Palms**  
Facility: Isle of Palms Public Safety Building  
Location: 30 JC Long Boulevard  
Isle of Palms, SC 29451  
Mailing Address: P.O. Box 508  
Isle of Palms, SC 29451  
County: Charleston  
Previous Orders: None  
Permit/ID Number: 19447  
Violations Cited: State Underground Petroleum Environmental Response Bank Act of 1988 (SUPERB Act) (2002 and Supp. 2014), and South Carolina Underground Storage Tank Control Regulation R.61-92.280.41(b)(1)(i) (Supp 2012).

Summary: The City of Isle of Palms (Individual/Entity) owns and operates underground storage tanks (USTs) located in Isle of Palms, South Carolina. On July 8, 2016, the Department conducted an inspection and issued a Notice of Alleged Violation because there was no automatic line leak detector on the Diesel UST at the time of the inspection. The Individual/Entity has violated the South Carolina Underground Storage Tank Regulation as follows: failure to equip a pressurized line with an automatic line leak detector. The Individual/Entity has submitted proof that an automatic line leak detector had been installed on the Diesel UST.

Action: The Individual/Entity is required to: pay a civil penalty in the amount of one thousand dollars (**\$1,000.00**).

8) Order Type and Number: Consent Order 16-0190-UST  
Order Date: September 1, 2016

Individual/Entity: **Eagle Transport Corporation**  
Facility: Kroger GA 678  
Location: 1025 Roberts Branch Parkway  
Columbia, SC  
Mailing Address: 300 South Wesleyan Blvd, Ste 202  
Rocky Mount, NC 27804  
County: Richland  
Previous Orders: None  
Permit/ID Number: 19809  
Violations Cited: State Underground Petroleum  
Environmental Response Bank Act of 1988 (SUPERB Act) (2002 and Supp.  
2014), and South Carolina Underground Storage Tank Control Regulation  
R.61-92.280.10(e) (Supp 2012).

Summary: Eagle Transport Corporation (Individual/Entity) supplied underground storage tanks (USTs) with petroleum/petroleum products located in Columbia, South Carolina. On July 20, 2016, the Department conducted an inspection and issued a Notice of Alleged Violation because deliveries had been made to an UST which did not hold a currently valid registration. The Individual/Entity has violated the South Carolina Underground Storage Tank Regulation as follows: introduction of petroleum or petroleum products into an UST for which the owner did not hold a currently valid registration.

Action: The Individual/Entity is required to: pay a civil penalty in the amount of one thousand dollars (**\$1,000.00**).

9) Order Type and Number: Consent Order 15-0448-UST  
Order Date: September 1, 2016  
Individual/Entity: **Rafat Abudayya**  
Facility: Hot Zone Mart  
Location: 401 Lockemy Highway  
Dillon, SC 29536  
Mailing Address: Same  
County: Dillon  
Previous Orders: None  
Permit/ID Number: 10297  
Violations Cited: The State Underground Petroleum  
Environmental Response Bank Act of 1988 (SUPERB Act), S.C. code Ann. § 44-  
2-10 *et seq.* (2002 and Supp. 2014); and South Carolina Underground Storage  
Tank Control Regulation, 7 S.C. Code Ann. Regs. 61-92.280.31(a), 61-  
92.280.34(c), 61-92.280.35(e), 61-92.280.35(f), 61-92.280.35(g), and 61-  
92.280.35(h) (Supp 2012).

Summary: Rafat Abudayya (Individual/Entity) owns and operates underground storage tanks (USTs) located in Dillon, South Carolina. On August 14, 2015, the Department conducted a routine inspection and issued a Notice of Alleged

Violation because the corrosion protection system test indicated failing results for the piping as if the piping was not tied into the corrosion protection system. On June 26, 2016, the Department conducted a routine inspection and issued a Notice of Alleged Violation because there was no A/B operator log and no list of C operators available at the time of the inspection. The Individual/Entity has violated the South Carolina Underground Storage Tank Control Regulation as follows: failed to operate and maintain all corrosion protection systems to continuously provide corrosion protection to the metal components of that portion of the piping that routinely contain regulated substances and are in contact with the ground; failed to provide records to the Department upon request; failed to validate monthly requirements have been performed; failed to physically visit each assigned facility once a quarter; failed to train C operators before they assumed responsibility for the UST system; and failed to designate in writing Class C operators and keep a copy at the facility.

Action: The Individual/Entity is required to: submit acceptable corrosion protection system test results, or permanently close the USTs; proof that an A/B log is being kept; a list of Class C operators; and, pay a civil penalty in the amount of three thousand, three hundred dollars **(\$3,300.00)** for the violations cited herein.

#### **Hazardous Waste Enforcement**

10) Order Type and Number: Consent Order 16-13-HW  
Order Date: September 19, 2016  
Individual/Entity: **ESAB Welding and Cutting Products**  
Facility: ESAB Welding and Cutting Products  
Location: 411 South Ebenezer Road  
Florence, SC 29501  
Mailing Address: 2800 Airport Road  
Denton, Texas 76207  
County: Florence  
Previous Orders: N/A  
Permit/ID Number: SCD 005 574 967  
Violations Cited: The South Carolina Hazardous Waste Management Act, S.C. Code Ann. §44-56-10 *et seq.* (2002 & Supp. 2015), the South Carolina Hazardous Waste Management Regulation, 6 and 7 S.C. Code Ann. Regs. 61-79 (2015), and the South Carolina Solid Waste Management: Used Oil Regulations, 8 S.C. Code Regs. 61-107.279 (2012).

Summary: ESAB Welding and Cutting Products (Individual/Entity) is a manufacturer of electrical welding and cutting equipment and supplies. On March 31, 2016, the Department conducted an inspection. The Individual/Entity violated the Hazardous Waste Management Regulations and the Solid Waste Management: Used Oil Regulations as follows: failed to accurately determine if a waste was a hazardous waste; failed to ensure that the date upon which each period of accumulation began

was clearly marked and visible for inspection on each container; failed to ensure while being accumulated onsite, each container was labeled or clearly marked with the EPA Hazardous Waste Number and the words: "Hazardous Waste – federal laws prohibit improper disposal;" failed to receive an extension from the Department granting hazardous waste to remain onsite for longer than 90 days; failed to manage universal waste lamps in a way that prevents releases by containing lamps in containers or packages that are kept closed, and structurally sound, adequate to prevent breakage, and compatible with the contents of the lamps; failed to ensure that each lamp or a container or package in which such lamps are contained is labeled or marked clearly with one of the following phrases: "Universal Waste – Lamp(s)," or "Waste Lamp(s)," or "Used Lamp(s);" failed to place universal waste in a container and mark or label the container with the earliest date that any universal waste in the container became a waste or was received; failed to review and immediately amend its contingency plan whenever the list of emergency coordinators changed; failed to ensure that facility personnel take part in an annual review of the initial training; failed to record inspections in an inspection log or summary; failed to inspect areas where containers are stored, at least weekly, looking for leaks and for deterioration caused by corrosion or other factors; failed to list the types and quantities of hazardous waste remaining in storage at the end of the fourth quarter reporting period for 2015; and, failed to label containers and aboveground tanks used to store used oil with the words "Used Oil."

Action: The Individual/Entity is required to: ensure future compliance with the South Carolina Hazardous Waste Management Act and Regulations and the South Carolina Solid Waste Policy and Management Act and Regulations; and, pay a civil penalty in the amount of twenty-six thousand dollars (**\$26,000.00**) in installments.

### **Solid Waste Enforcement**

11)	<u>Order Type and Number:</u> <u>Order Date:</u> <u>Individual/Entity:</u> <u>Facility:</u> <u>Location:</u>  <u>Mailing Address:</u> <u>County:</u> <u>Previous Orders:</u> <u>Permit/ID Number:</u> <u>Violations Cited:</u>	Consent Order 16-15-SW September 13, 2016 <b>Dana Moore</b> USA Waste and Recycling 1972 Harry Byrd Blvd. Darlington, SC Same Darlington N/A None The South Carolina Solid Waste Policy and Management Act of 1991, S.C. Code Ann. 44-96-10 <u>et seq.</u> (2002 & Supp. 2014), Solid Waste Landfills and Structural Fill, R. 61-107.19 (Supp. 2012), and 8 S.C. Code Ann. Regs., R. 61-107.3 (2015) (Waste Tires).
-----	--	---



Summary: Dana Moore (Individual/Entity) operates a recycling business located in Darlington, South Carolina. On January 14, 2016, the Department issued a Notice of Alleged Violation/Notice of Enforcement Conference regarding the large amount of recyclable material/solid waste stored on the Site. The Individual/Entity has violated the South Carolina Solid Waste Policy and Management Act of 1991, the South Carolina Solid Waste Landfills and Structural Fill Regulation, and the South Carolina Waste Tire Regulation as follows: operated a solid waste management facility without a permit, operated a Class Three Landfill without a permit, operated a waste tire collection facility without a permit and hauling waste tires without registering with the Department.

Action: The Individual/Entity is required to: discontinue collecting and hauling tires; remove and dispose of all solid waste and waste tires at the Site in a permitted solid waste collection or recycling facility; provide disposal receipts; and, pay a **suspended penalty** in the amount of forty thousand, seven hundred fifty dollars (**\$40,750.00**) should any requirement of the Order not be met.

## **BUREAU OF WATER**

### **Recreational Water Enforcement**

12)	<u>Order Type and Number:</u>	Consent Order 16-087-RW
	<u>Order Date:</u>	September 6, 2016
	<u>Individual/Entity:</u>	<b>Hilton Head Hospitality, LLC</b>
	<u>Facility:</u>	Grand Hilton Head Inn
	<u>Location:</u>	36 South Forest Beach Drive
	<u>Mailing Address:</u>	Same
	<u>County:</u>	Beaufort
	<u>Previous Orders:</u>	None
	<u>Permit/ID Number:</u>	07-406-1
	<u>Violations Cited:</u>	S.C. Code Ann. Regs. 61-51(J)

Summary: Hilton Head Hospitality, LLC (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On June 15, 2016, and July 7, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: a skimmer was missing a weir; the pH level was not within the acceptable range of water quality standards; there were no "Shallow Water – No Diving Allowed" signs posted on the first inspection and only one sign was posted on the second inspection; there were no "No Lifeguard On Duty – Swim At Your Own Risk" signs posted; the deck was not clean or clear of hazards; the gate did not self-close and latch; there was no drinking water fountain; the emergency notification device was not operational; the facility could not produce current valid documentation of pool operator certification; and, the bound and



Mailing Address: Blythewood, South Carolina 29016  
County: Same  
Previous Orders: Richland  
Permit/ID Number: None  
Violations Cited: 40-381-1  
S.C. Code Ann. Regs. 61-51(J)

Summary: M and M Corporation of South Carolina (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On June 13, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: a handrail was missing a bolt cover; the gate did not self-close and latch; the drinking water fountain and foot rinse shower were not operating properly; the step edge tile stripe was not within one inch of the edge of the step; the chlorine and pH levels were not within the acceptable range of water quality standards; the cyanuric acid level was above the water quality standards acceptable limit; the life ring was deteriorated; the pool rules sign was not legible; and, the bound and numbered log book was not available for review.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of three hundred forty dollars (**\$340.00**).

15) Order Type and Number: Consent Order 16-090-RW  
Order Date: September 6, 2016  
Individual/Entity: **Shellring Property Owners Association, Inc.**  
Facility: Shellring  
Location: 110 Salt Meadow Lane  
St. Thomas Island, SC 29492  
Mailing Address: Same  
County: Charleston  
Previous Orders: None  
Permit/ID Number: 10-1150B  
Violations Cited: S.C. Code Ann. Regs. 61-51(J) & 61-51(K)(1)(c)

Summary: Shellring Property Owners Association, Inc. (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On June 23, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain; and, on July 6, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain, and for re-opening prior to receiving Department approval. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: a skimmer was missing a weir; the chlorine and pH levels were not within the acceptable range of water quality standards; the shepherd's crook was held together with zip ties; the emergency notification device

was not operational; the chlorinator was overflowing; and, the pool was operating prior to receiving Department approval.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of one thousand twenty dollars **(\$1,020.00)**. The civil penalty has been paid.

16)	<u>Order Type and Number:</u>	Consent Order 16-091-RW
	<u>Order Date:</u>	September 6, 2016
	<u>Individual/Entity:</u>	<b>Hilton Head Island Hotel Partners II, LLC</b>
	<u>Facility:</u>	Holiday Inn Express Hilton Head Island
	<u>Location:</u>	2 Tanglewood Drive Beaufort, SC 29928
	<u>Mailing Address:</u>	Same
	<u>County:</u>	Beaufort
	<u>Previous Orders:</u>	None
	<u>Permit/ID Number:</u>	07-350-1
	<u>Violations Cited:</u>	S.C. Code Ann. Regs. 61-51(J)

Summary: Hilton Head Island Hotel Partners II, LLC (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On June 10, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: the gate did not self-close and latch; the foot rinse shower was not operational; there was no drinking water fountain; the life ring did not have a permanently attached rope; there was no shepherd's crook; the pool rules sign was not completely filled out; only one "Shallow Water – No Diving Allowed" sign was posted; the "No Lifeguard On Duty – Swim At Your Own Risk" signs did not have the correct wording; and, the facility could not produce current valid documentation of pool operator certification. On June 13, 2016, a follow-up inspection was conducted and it was determined that all of the deficiencies had been addressed.

Action: The Individual/Entity is required to: pay a civil penalty in the amount of three hundred forty dollars **(\$340.00)**.

17)	<u>Order Type and Number:</u>	Consent Order 16-092-RW
	<u>Order Date:</u>	September 6, 2016
	<u>Individual/Entity:</u>	<b>Atrium TRS I, LP</b>
	<u>Facility:</u>	Embassy Suites Columbia
	<u>Location:</u>	200 Stoneridge Drive Columbia, SC 29210
	<u>Mailing Address:</u>	12735 Morris Road Ext., Suite 400

<u>County:</u>	Alpharetta, GA 30004
<u>Previous Orders:</u>	Richland
<u>Permit/ID Number:</u>	None
<u>Violations Cited:</u>	40-263-1
	S.C. Code Ann. Regs. 61-51(J)

Summary: Atrium TRS I, LP (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On May 20, 2016, and June 20, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: the pool floor was not clean; the pool furniture was not at least four feet from the pool edge; the deck drains were broken; the water level was too low; a skimmer was missing a weir; the "Shallow Water – No Diving Allowed" signs were not the appropriate size and did not have the appropriate wording; only one of the "No Lifeguard On Duty – Swim At Your Own Risk" signs was posted during the first inspection, and the signs were obstructed by pool furniture during the second inspection; the pool walls were not clean; the gate did not self-close and latch; an inlet plug was not in place on the pool floor; a handrail was missing a bolt cover; the chlorine level was not within the acceptable range of water quality standards; the pool rules sign did not have all of the required rules; and, the current pool operator of record information was not posted to the public.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of six hundred eighty dollars (**\$680.00**). The civil penalty has been paid. The Individual/Entity submitted a corrective action plan and corrected the deficiencies.

18)	<u>Order Type and Number:</u>	Consent Order 16-093-RW
	<u>Order Date:</u>	September 6, 2016
	<u>Individual/Entity:</u>	<b>Atrium TRS III, LP</b>
	<u>Facility:</u>	Embassy Suites Greenville
	<u>Location:</u>	670 Verdae Boulevard Greenville, SC 29607
	<u>Mailing Address:</u>	12735 Morris Road Ext., Suite 400 Alpharetta, GA 30004
	<u>County:</u>	Greenville
	<u>Previous Orders:</u>	None
	<u>Permit/ID Number:</u>	23-376-1
	<u>Violations Cited:</u>	S.C. Code Ann. Regs. 61-51(J)

Summary: Atrium TRS III, LP (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On February 11, 2016, May 20, 2016, and June 17, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: the life ring did not have a permanently

attached rope; the chlorine level was not within the acceptable range of water quality standards; the cyanuric acid level was above the water quality standards acceptable limit and the levels were not being logged weekly; and, the "No Lifeguard On Duty - Swim At Your Own Risk" signs posted did not have the correct wording.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of two thousand forty dollars **(\$2,040.00)**.

19) Order Type and Number: Consent Order 16-094-RW  
Order Date: September 6, 2016  
Individual/Entity: **Battery Point Homeowners Association, Inc.**  
Facility: Battery Point  
Location: Old Salem Road  
Beaufort, SC 29901  
Mailing Address: 3 Bostick Circle  
Beaufort, SC 29902  
County: Beaufort  
Previous Orders: 14-208-DW (\$800.00)  
Permit/ID Number: 07-506-1  
Violations Cited: S.C. Code Ann. Regs. 61-51(J)

Summary: Battery Point Homeowners Association, Inc. (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On May 31, 2016, and July 7, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: the pool floor was not clean; there was algae on the walls and floor of the pool; a skimmer was missing a weir; the chlorine level was not within the acceptable range of water quality standards; the facility could not produce current valid documentation of pool operator certification; and, the bound and numbered log book was not maintained on a daily basis.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of one thousand, one hundred twenty dollars **(\$1,120.00)**.

20) Order Type and Number: Consent Order 16-095-RW  
Order Date: September 7, 2016  
Individual/Entity: **Hilton Head Hotel Investments, LP**  
Facility: Sleep Inn Beaufort  
Location: 2523 Boundary Street  
Beaufort, SC 29906  
Mailing Address: Same  
County: Beaufort

Previous Orders: None  
Permit/ID Number: 07-551-1  
Violations Cited: S.C. Code Ann. Regs. 61-51(J)

Summary: Hilton Head Hotel Investments, LP (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On June 1, 2016, and July 8, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: a skimmer was missing a weir; the chlorine level was not within the acceptable range of water quality standards; a handrail was not tight and secure; and, the facility could not produce current valid documentation of pool operator certification.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of six hundred eighty dollars **(\$680.00)**.

21) Order Type and Number: Consent Order 16-096-RW  
Order Date: September 12, 2016  
Individual/Entity: **Pracha, LLC**  
Facility: Crossroads Inn and Suites  
Location: 2376 Highway 501 East  
Conway, SC 29526  
Mailing Address: Same  
County: Horry  
Previous Orders: None  
Permit/ID Number: 26-875-1  
Violations Cited: S.C. Code Ann. Regs. 61-51(J)

Summary: Pracha, LLC (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On July 6, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: there was no lifeline; a ladder did not have bumpers; the gate did not self-close and latch; there was no drinking water fountain, foot rinse shower or shepherd's crook; the emergency notification device was not operating properly; the facility address was not posted at the emergency notification device; the pool rules sign was not completely filled out; only one "Shallow Water - No Diving Allowed" sign was posted; only one "No Lifeguard On Duty - Swim At Your Own Risk" sign was posted; the current pool operator of record information was not posted; and, the bound and numbered log book was not available for review.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of three hundred forty dollars **(\$340.00)**. The civil penalty has been

paid. On July 7, 2016, a follow-up inspection was conducted and it was determined that all of the deficiencies had been corrected.

22) Order Type and Number: Consent Order 16-097-RW  
Order Date: September 8, 2016  
Individual/Entity: **Paramount Hotels, LLC**  
Facility: Hampton Inn Newberry  
Location: 1201 Nance Street  
Newberry, SC 29108  
Mailing Address: P.O. Box 949  
Blythewood, SC 29016  
County: Newberry  
Previous Orders: None  
Permit/ID Number: 36-1001B  
Violations Cited: S.C. Code Ann. Regs. 61-51(J) & 61-51(I)

Summary: Paramount Hotels, LLC (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On June 21, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain, and for failure to submit to the Department for approval a Swimming Pool Change Order Request Form prior to modifying the pool. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: depth marker tiles were cracked; a ladder was not tight and secure; the pool floor was not clean; the pool furniture was not at least four feet from the pool edge; the deck drains were broken; the chlorine and pH levels were not within the acceptable range of water quality standards; the life ring was deteriorated; the facility address was not posted at the emergency notification device; the pool rules sign was not completely filled out; the current pool operator of record information was not posted to the public; the bound and numbered log book was not maintained on a daily basis; and, a Swimming Pool Change Order Request Form was not submitted to the Department for approval prior to modifying the pool.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of five hundred ten dollars (**\$510.00**). The Individual/Entity submitted a Swimming Pool Change Order Request Form and it has been approved by the Department.

23) Order Type and Number: Consent Order 16-098-RW  
Order Date: September 12, 2016  
Individual/Entity: **Queens Grant Regime, II, Inc.**  
Facility: Queens Grant II  
Location: 21 Executive Park Road  
Hilton Head Island, SC 29928  
Mailing Address: Same



County: Beaufort  
Previous Orders: None  
Permit/ID Number: 07-065-1  
Violations Cited: S.C. Code Ann. Regs. 61-51(J)

Summary: Queens Grant Regime, II, Inc. (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On June 3, 2016, and July 12, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: the lifeline was not attached to the pool wall on the first inspection and the lifeline floats were damaged on the second inspection; a skimmer was missing a weir; the pH level was not within the acceptable range of water quality standards; the pool rules sign was not legible; the facility could not produce current valid documentation of pool operator certification; and, the bound and numbered log book was not maintained on a daily basis.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of six hundred eighty dollars **(\$680.00)**.

24) Order Type and Number: Consent Order 16-099-RW  
Order Date: September 12, 2016  
Individual/Entity: **Two Bridges Valley Creek, LLC**  
Facility: Valley Creek Apartments  
Location: 9085 Fairforest Road  
Spartanburg, SC 29303  
Mailing Address: Same  
County: Spartanburg  
Previous Orders: None  
Permit/ID Number: 42-049-1  
Violations Cited: S.C. Code Ann. Regs. 61-51(J)

Summary: Two Bridges Valley Creek, LLC (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On May 23, 2016, and July 8, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: the pH level was not within the acceptable range of water quality standards; the emergency notification device was not operational; the bound and numbered log book was not maintained on a daily basis; and, the life ring was not United States Coast Guard approved.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of six hundred eighty dollars **(\$680.00)**.

25)	<u>Order Type and Number:</u>	Consent Order 16-100-RW
	<u>Order Date:</u>	September 12, 2016
	<u>Individual/Entity:</u>	<b>Lakeside Country Club</b>
	<u>Facility:</u>	Lakeside Country Club
	<u>Location:</u>	1 Country Club Drive Laurens, SC 29360
	<u>Mailing Address:</u>	Same
	<u>County:</u>	Laurens
	<u>Previous Orders:</u>	None
	<u>Permit/ID Number:</u>	30-036-1
	<u>Violations Cited:</u>	S.C. Code Ann. Regs. 61-51(J)

Summary: Lakeside Country Club (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On June 13, 2016, and July 15, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: a ladder was not tight and secure; the drinking water fountain was not operating properly; the chlorine level was not within the acceptable range of water quality standards; the shepherd's crook was not permanently attached to the handle and was missing a bolt; the emergency notification device was not accessible; the pump room was not accessible; the skimmer lids were cracked; the gate did not self-close and latch; and, one of the "Shallow Water - No Diving Allowed" signs was damaged.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of six hundred eighty dollars **(\$680.00)**.

26)	<u>Order Type and Number:</u>	Consent Order 16-101-RW
	<u>Order Date:</u>	September 12, 2016
	<u>Individual/Entity:</u>	<b>Isle of Palms Beach Club Villas Owners Association, Inc.</b>
	<u>Facility:</u>	Beach Club Villas #2
	<u>Location:</u>	Beach Club Villas Court Isle of Palms, SC 29451
	<u>Mailing Address:</u>	Same
	<u>County:</u>	Charleston
	<u>Previous Orders:</u>	None
	<u>Permit/ID Number:</u>	10-192-1
	<u>Violations Cited:</u>	S.C. Code Ann. Regs. 61-51(J)

Summary: Isle of Palms Beach Club Villas Owners Association, Inc. (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On May 25, 2016, and July 8, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: a

ladder was not tight and secure and was missing bumpers; the skimmers were missing weirs; the gate did not self-close and latch; the shepherd's crook was not clear of obstructions; the emergency notification device was not operational; the pH level was not within the acceptable range of water quality standards; and, the life ring was deteriorated.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of six hundred eighty dollars **(\$680.00)**. The Individual/Entity submitted a corrective action plan and corrected the deficiencies.

27)	<u>Order Type and Number:</u>	Consent Order 16-102-RW
	<u>Order Date:</u>	September 12, 2016
	<u>Individual/Entity:</u>	<b>Braxton E. Lewis, Individually and d.b.a. Pelican Cay</b>
	<u>Facility:</u>	Pelican Cay
	<u>Location:</u>	200 6 <sup>th</sup> Avenue South North Myrtle Beach, SC 29582
	<u>Mailing Address:</u>	P.O. Box 298 North Myrtle Beach, SC 29597
	<u>County:</u>	Horry
	<u>Previous Orders:</u>	None
	<u>Permit/ID Number:</u>	26-K30-1
	<u>Violations Cited:</u>	S.C. Code Ann. Regs. 61-51(J)

Summary: Braxton E. Lewis, Individually and d.b.a. Pelican Cay (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On June 2, 2016, and June 28, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: there was debris in the skimmer baskets; the pool walls were not clean; there was no drinking water fountain; the chlorine and pH levels were not within the acceptable range of water quality standards; the shepherd's crook was missing a bolt; and, the bound and numbered log book was not maintained on a daily basis.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of six hundred eighty dollars **(\$680.00)**. The civil penalty has been paid.

28)	<u>Order Type and Number:</u>	Consent Order 16-103-RW
	<u>Order Date:</u>	September 13, 2016
	<u>Individual/Entity:</u>	<b>Rivendell Homeowner's Association, Inc.</b>
	<u>Facility:</u>	Rivendell

Location: 103 Shire Drive  
Anderson, SC 29621  
Mailing Address: Same  
County: Anderson  
Previous Orders: None  
Permit/ID Number: 04-1018B  
Violations Cited: S.C. Code Ann. Regs. 61-51(J)

Summary: Rivendell Homeowner's Association, Inc. (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On June 8, 2016, and July 19, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: a handrail was not tight and secure; there was debris in the skimmer baskets; the pH level was not within the acceptable range of water quality standards; the facility could not produce current valid documentation of pool operator certification; the log book was not properly bound and was not maintained on a daily basis; and, only one "No Lifeguard On Duty - Swim At Your Own Risk" sign was posted.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of six hundred eighty dollars (**\$680.00**).

29) Order Type and Number: Consent Order 16-104-RW  
Order Date: September 15, 2016  
Individual/Entity: **Quinine Hill Homeowners Association, Inc.**  
Facility: Quinine Hill  
Location: 7 Quinine Hill  
Columbia, SC 29204  
Mailing Address: Same  
County: Richland  
Previous Orders: None  
Permit/ID Number: 40-146-1  
Violations Cited: S.C. Code Ann. Regs. 61-51(J) & 61-51(K)(1)(c)

Summary: Quinine Hill Homeowners Association, Inc. (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On July 13, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain; and, on July 13, 2016, a follow-up inspection was conducted, and a violation was issued for failure to properly operate and maintain and for re-opening prior to receiving Department approval. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: a handrail was not tight and secure; the gate did not self-close and latch; there was no drinking water fountain; the chlorine and pH levels were not within the acceptable range of water quality

standards; the emergency notification device was not operational; the bound and numbered log book was not maintained on a daily basis; a ladder was not tight and secure; the pool walls were dirty; and, the pool was operating prior to receiving Department approval.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of one thousand twenty dollars **(\$1,020.00)**.

30) Order Type and Number: Consent Order 16-105-RW  
Order Date: September 15, 2016  
Individual/Entity: **Queens Grant Villas Horizontal Property Regime V, Individually and d.b.a. Queens Grant V**  
Facility: Queens Grant V  
Location: 21 Executive Park Road  
Hilton Head Island, SC 29928  
Mailing Address: Same  
County: Beaufort  
Previous Orders: None  
Permit/ID Number: 07-062-1  
Violations Cited: S.C. Code Ann. Regs. 61-51(J)

Summary: Queens Grant Villas Horizontal Property Regime V, Individually and d.b.a. Queens Grant V (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On June 3, 2016, and July 12, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: a ladder was missing bumpers; a skimmer was missing a weir; the chlorine and pH levels were not within the acceptable range of water quality standards; and, the facility could not produce current valid documentation of pool operator certification.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of six hundred eighty dollars **(\$680.00)**.

31) Order Type and Number: Consent Order 16-106-RW  
Order Date: September 15, 2016  
Individual/Entity: **Pine Island I Homeowners Association and Pine Island II Homeowners Association**  
Facility: Pine Island Homes  
Location: 17 Pine Island Court  
Hilton Head Island, SC 29928

Mailing Address: Same  
County: Beaufort  
Previous Orders: None  
Permit/ID Number: 07-178-1  
Violations Cited: S.C. Code Ann. Regs. 61-51(J)

Summary: Pine Island I Homeowners Association and Pine Island II Homeowners Association (Individual/Entity) own and are responsible for the proper operation and maintenance of a pool. On June 8, 2016, and July 13, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: the lifeline floats were cracked; a skimmer was missing a weir; the gate did not self-close and latch; the chlorine level was not within the acceptable range of water quality standards; and, the facility could not produce current valid documentation of pool operator certification.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of six hundred eighty dollars (**\$680.00**). The civil penalty has been paid. The Individual/Entity submitted a corrective action plan and corrected the deficiencies.

32) Order Type and Number: Consent Order 16-107-RW  
Order Date: September 19, 2016  
Individual/Entity: **The Groves Homes Association**  
Facility: The Groves Townhomes  
Location: Cactus Road  
Columbia, SC 29202  
Mailing Address: P.O. Box 2014  
Lexington, SC 29071  
County: Richland  
Previous Orders: None  
Permit/ID Number: 40-046-1  
Violations Cited: S.C. Code Ann. Regs. 61-51(J)

Summary: The Groves Homes Association (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On June 3, 2016, and July 8, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: a ladder was not tight and secure; the bathrooms were not clean and did not have soap; the pool floor was discolored; there was dirt and oil on the waterline tiles; the water level was too high; there was no drinking water fountain; the chlorine level was not within the acceptable range of water quality standards; the facility address was not posted at the emergency notification device; the pool rules sign was cracked; only one "No Lifeguard On Duty – Swim At Your Own Risk" sign was posted on the first inspection, and one of the

signs posted on the second inspection was cracked; the bound and numbered log book was not available for review; and, the pump room was not accessible.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of six hundred eighty dollars (**\$680.00**).

33)	<u>Order Type and Number:</u>	Consent Order 16-108-RW
	<u>Order Date:</u>	September 19, 2016
	<u>Individual/Entity:</u>	<b>Hampton Oaks Apartments, LLC</b>
	<u>Facility:</u>	Hampton Oaks Apartments
	<u>Location:</u>	6600 Rivers Avenue North Charleston, SC 29406
	<u>Mailing Address:</u>	Same
	<u>County:</u>	Charleston
	<u>Previous Orders:</u>	None
	<u>Permit/ID Number:</u>	08-005-1
	<u>Violations Cited:</u>	S.C. Code Ann. Regs. 61-51(J)

Summary: Hampton Oaks Apartments, LLC (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On June 30, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: the lifeline floats were not properly spaced; a handrail and ladder were not tight and secure; a ladder was missing bumpers; there was no foot rinse shower; the pH level was not within the acceptable range of water quality standards; the life ring was deteriorated; the facility could not produce current valid documentation of pool operator certification; the bound and numbered log book was not available for review; and, the pump room was not accessible.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of three hundred forty dollars (**\$340.00**).

34)	<u>Order Type and Number:</u>	Consent Order 16-109-RW
	<u>Order Date:</u>	September 19, 2016
	<u>Individual/Entity:</u>	<b>Bees Ferry-FCA, LLC</b>
	<u>Facility:</u>	Bees Ferry Apartments
	<u>Location:</u>	2020 Proximity Drive Charleston, SC 29414
	<u>Mailing Address:</u>	201 South Trion Street, Suite 900 Charlotte, NC 28202
	<u>County:</u>	Charleston
	<u>Previous Orders:</u>	None
	<u>Permit/ID Number:</u>	10-1216B

Violations Cited:

S.C. Code Ann. Regs. 61-51(J)

Summary: Bees Ferry-FCA, LLC (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On May 25, 2016, and July 7, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: the gate did not self-close and latch; the foot rinse shower was not operating; the chlorine and pH levels were not within the acceptable range of water quality standards; the emergency notification device was not operating; the pool rules sign did not have all of the required rules; and, the current pool operator of record information was not posted to the public.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of six hundred eighty dollars **(\$680.00)**.

35)	<u>Order Type and Number:</u>	Consent Order 16-110-RW
	<u>Order Date:</u>	September 19, 2016
	<u>Individual/Entity:</u>	<b>Nicobar, LTD</b>
	<u>Facility:</u>	Beachwalk Motel
	<u>Location:</u>	1701 South Ocean Boulevard Myrtle Beach, SC 29577
	<u>Mailing Address:</u>	Same
	<u>County:</u>	Horry
	<u>Previous Orders:</u>	13-104-DW (\$680.00)
	<u>Permit/ID Number:</u>	26-368-1 & 26-368-2
	<u>Violations Cited:</u>	S.C. Code Ann. Regs. 61-51(J)

Summary: Nicobar, LTD (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool and a kiddie pool. On May 31, 2016, the pool and kiddie pool were inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: the pool and kiddie pool floor were not clean; the water level was too low; the gate did not self-close and latch; there was no drinking water fountain or foot rinse shower; the pH level was not within the acceptable range of water quality standards; the pool rules sign was missing; the facility could not produce current valid documentation of pool operator certification; and, the bound and numbered log book was not maintained on a daily basis.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of eight hundred forty dollars **(\$840.00)**.

36)	<u>Order Type and Number:</u>	Consent Order 16-111-RW
	<u>Order Date:</u>	September 20, 2016



<u>Individual/Entity:</u>	<b>Oxford-Columbia 25, LLC</b>
<u>Facility:</u>	Courtyard by Marriott
<u>Location:</u>	111 Gateway Corporate Blvd Columbia, SC 29203
<u>Mailing Address:</u>	Same
<u>County:</u>	Richland
<u>Previous Orders:</u>	None
<u>Permit/ID Number:</u>	40-383-1
<u>Violations Cited:</u>	S.C. Code Ann. Regs. 61-51(J)

Summary: Oxford-Columbia 25, LLC (Individual/Entity) owns and is responsible for the proper operation and maintenance of a spa. On June 6, 2016, and July 14, 2016, the spa was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: there was no foot rinse shower; the chlorine and pH levels were not within the acceptable range of water quality standards; the current pool operator of record information was not posted to the public; the bound and numbered log book was not maintained a minimum of three times per week by the pool operator of record; and, the pool rules sign was not completely filled out.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of six hundred eighty dollars (**\$680.00**).

37) <u>Order Type and Number:</u>	Consent Order 16-112-RW
<u>Order Date:</u>	September 20, 2016
<u>Individual/Entity:</u>	<b>Monument St. Andrew's, LLC</b>
<u>Facility:</u>	St. Andrews Apartments
<u>Location:</u>	601 St. Andrews Road Columbia, SC 29210
<u>Mailing Address:</u>	5200 Blue Lagoon Drive, Suite 400 Miami, FL 33126
<u>County:</u>	Lexington
<u>Previous Orders:</u>	None
<u>Permit/ID Number:</u>	32-064-1
<u>Violations Cited:</u>	S.C. Code Ann. Regs. 61-51(J)

Summary: Monument St. Andrew's, LLC (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On June 10, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: the lifeline floats were not properly spaced; a ladder was not tight and secure; the depth marker tiles at the waterline were broken; there was dirt and oil on the waterline tiles; there were cracks on the pool deck; the gate did not self-close and latch; the drinking water fountain was not within fifty feet of the pool; there was no foot rinse shower; the chlorine level was not within the acceptable range of water

quality standards; the main drain grates were not visible because the water was too cloudy; the life ring rope was not permanently attached to the life ring; the shepherd's crook was not properly mounted in its designated location; and, the bound and numbered log book was not maintained on a daily basis, and was not maintained a minimum of three times per week by the pool operator of record.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of three hundred forty dollars **(\$340.00)**.

38)	<u>Order Type and Number:</u>	Consent Order 16-113-RW
	<u>Order Date:</u>	September 20, 2016
	<u>Individual/Entity:</u>	<b>The Shorewood Common Property Owners Association, Inc.</b>
	<u>Facility:</u>	Shorewood Villas
	<u>Location:</u>	21 Forest Beach Drive Hilton Head Island, SC 29928
	<u>Mailing Address:</u>	Same
	<u>County:</u>	Beaufort
	<u>Previous Orders:</u>	None
	<u>Permit/ID Number:</u>	07-1172C
	<u>Violations Cited:</u>	S.C. Code Ann. Regs. 61-51(J)

Summary: The Shorewood Common Property Owners Association, Inc. (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On May 27, 2016, and July 6, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: the gate did not self-close and latch; the chlorine and pH levels were not within the acceptable range of water quality standards; and, the facility could not produce current valid documentation of pool operator certification.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of six hundred eighty dollars **(\$680.00)**.

39)	<u>Order Type and Number:</u>	Consent Order 16-114-RW
	<u>Order Date:</u>	September 20, 2016
	<u>Individual/Entity:</u>	<b>Wappoo Creek Place Owners Association</b>
	<u>Facility:</u>	Wappoo Creek Place
	<u>Location:</u>	40 Wappoo Creek Place Charleston, SC 29412
	<u>Mailing Address:</u>	Same
	<u>County:</u>	Charleston

Previous Orders: None  
Permit/ID Number: 10-200-1  
Violations Cited: S.C. Code Ann. Regs. 61-51(J)

Summary: Wappoo Creek Place Owners Association (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On June 2, 2016, and July 11, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: the bathrooms did not have soap; the chlorine and pH levels were not within the acceptable range of water quality standards; the life ring did not have a permanently attached rope; there was only one "Shallow Water - No Diving Allowed" sign; the lifeline with floats was not attached to the pool wall; and, the bound and numbered log book was not maintained on a daily basis.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of six hundred eighty dollars **(\$680.00)**.

40) Order Type and Number: Consent Order 16-115-RW  
Order Date: September 20, 2016  
Individual/Entity: **Beaufort Lodging, LLC**  
Facility: Hampton Inn Beaufort  
Location: 2342 Boundary Street  
Beaufort, SC 29902  
Mailing Address: Same  
County: Beaufort  
Previous Orders: None  
Permit/ID Number: 07-502-1  
Violations Cited: S.C. Code Ann. Regs. 61-51(J)

Summary: Beaufort Lodging, LLC (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On May 31, 2016, and July 8, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: the drinking water fountain and the foot rinse shower were not operating properly; the chlorine and pH levels were not within the acceptable range of water quality standards; the pool rules sign was not completely filled out; the facility could not produce current valid documentation of pool operator certification; and, the bound and numbered log book was not maintained on a daily basis.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of six hundred eighty dollars **(\$680.00)**. The civil penalty has been paid.

41) Order Type and Number: Consent Order 16-116-RW  
Order Date: September 20, 2016  
Individual/Entity: **Tilghman Forest Homeowners Association**  
Facility: Tilghman Forest  
Location: 1020 Tilghman Forest Drive  
North Myrtle Beach, SC 29582  
Mailing Address: 1114 Swan Lake Drive  
North Myrtle Beach, SC 29582  
County: Horry  
Previous Orders: None  
Permit/ID Number: 26-L06-1  
Violations Cited: S.C. Code Ann. Regs. 61-51(J)

Summary: Tilghman Forest Homeowners Association (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On June 10, 2016, and June 30, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: the pH level was not within the acceptable range of water quality standards; there was no pool rules sign posted; only one "No Lifeguard On Duty – Swim At Your Own Risk" sign was posted; and, the current pool operator of record information was not posted to the public.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of six hundred eighty dollars (**\$680.00**).

42) Order Type and Number: Consent Order 16-117-RW  
Order Date: September 21, 2016  
Individual/Entity: **Bodyshop Athletics, Inc.**  
Facility: Top Spin Tennis Club  
Location: 5347 B Sunset Boulevard  
Lexington, SC 29072  
Mailing Address: Same  
County: Lexington  
Previous Orders: None  
Permit/ID Number: 32-142-1  
Violations Cited: S.C. Code Ann. Regs. 61-51(J)

Summary: Bodyshop Athletics, Inc. (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On May 25, 2016, and July 18, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: the gate did not self-close and latch; the life ring did not have a permanently attached rope; the shepherd's crook was missing a bolt and was not

permanently attached to the handle; the bound and numbered log book was not available for review on the first inspection, and was not maintained a minimum of three times per week by the pool operator of record on the second inspection; the chlorine level was not within the acceptable range of water quality standards; and, only one "No Lifeguard On Duty - Swim At Your Own Risk" sign was posted.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of six hundred eighty dollars (**\$680.00**). The civil penalty has been paid. The Individual/Entity submitted a corrective action plan and corrected the deficiencies.

43)	<u>Order Type and Number:</u>	Consent Order 16-118-RW
	<u>Order Date:</u>	September 26, 2016
	<u>Individual/Entity:</u>	<b>The Pier at Clemson, LLC</b>
	<u>Facility:</u>	The Pier Apartments
	<u>Location:</u>	440 Edinburgh Way Seneca, SC 29678
	<u>Mailing Address:</u>	918 Queens Park Loop Seneca, SC 29678
	<u>County:</u>	Oconee
	<u>Previous Orders:</u>	None
	<u>Permit/ID Number:</u>	37-1019D
	<u>Violations Cited:</u>	S.C. Code Ann. Regs. 61-51(J)

Summary: The Pier at Clemson, LLC (Individual/Entity) owns and is responsible for the proper operation and maintenance of a spa. On July 7, 2016, and August 8, 2016, the spa was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: the gate did not self-close and latch; a section of the perimeter fencing had openings greater than four inches; the drinking water fountain was not operating properly; the foot rinse shower was not operating properly; the chlorine and pH levels were not within the acceptable range of water quality standards; the emergency notification device was not operating; the spa rules sign was not completely filled out; and, the "No Lifeguard On Duty - Swim At Your Own Risk" signs did not have the correct wording and the lettering was not the appropriate size.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of six hundred eighty dollars (**\$680.00**). The Individual/Entity submitted a corrective action plan and corrected the deficiencies.

44)	<u>Order Type and Number:</u>	Consent Order 16-119-RW
	<u>Order Date:</u>	September 26, 2016

<u>Individual/Entity:</u>	<b>Seaside Inn Owners Association, Inc.</b>
<u>Facility:</u>	Seaside Inn
<u>Location:</u>	1004 Ocean Boulevard Isle of Palms, SC 29451
<u>Mailing Address:</u>	Same
<u>County:</u>	Charleston
<u>Previous Orders:</u>	None
<u>Permit/ID Number:</u>	10-1126B
<u>Violations Cited:</u>	S.C. Code Ann. Regs. 61-51(J)

Summary: Seaside Inn Owners Association, Inc. (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On May 27, 2016, and July 11, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: a ladder was missing bumpers; the plaster on the pool floor was delaminated; a skimmer was missing a weir; the deck was not clean and clear of hazards; there was no drinking water fountain; and, the chlorine level was not within the acceptable range of water quality standards.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of six hundred eighty dollars (**\$680.00**).

45) <u>Order Type and Number:</u>	Consent Order 16-120-RW
<u>Order Date:</u>	September 27, 2016
<u>Individual/Entity:</u>	<b>Myrbeach Mortgage, LLC</b>
<u>Facility:</u>	Days Inn
<u>Location:</u>	3650 Waccamaw Boulevard Myrtle Beach, SC 29579
<u>Mailing Address:</u>	Same
<u>County:</u>	Horry
<u>Previous Orders:</u>	13-068-DW (\$400.00) 15-043-RW (\$1,360.00)
<u>Permit/ID Number:</u>	26-A67-1
<u>Violations Cited:</u>	S.C. Code Ann. Regs. 61-51(J)

Summary: Myrbeach Mortgage, LLC (Individual/Entity) owns and is responsible for the proper operation and maintenance of a spa. On June 14, 2016, the spa was inspected and a violation was issued for failure to properly operate and maintain. The Individual//Entity has violated the Public Swimming Pools Regulation as follows: the foot rinse shower was not operating properly; the chlorine level was not within the acceptable range of water quality standards; and, the cyanuric acid level was above the water quality standards acceptable limit.

Action: The Individual//Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and pay a civil penalty in the amount of one thousand, three hundred sixty dollars (**\$1,360.00**). The civil penalty has been paid.

46) Order Type and Number: Consent Order 16-121-RW  
Order Date: September 27, 2016  
Individual/Entity: **Wave Rider Resort Homeowners Association, Inc.**  
Facility: Wave Rider Motel  
Location: 1600 South Ocean Boulevard  
North Myrtle Beach, SC 29577  
Mailing Address: Same  
County: Horry  
Previous Orders: None  
Permit/ID Number: 26-243-1 & 26-545-1  
Violations Cited: S.C. Code Ann. Regs. 61-51(J)

Summary: Wave Rider Resort Homeowners Association, Inc. (Individual/Entity) owns and is responsible for the proper operation and maintenance of two pools. On May 25, 2016, and July 19, 2016, the pools were inspected and violations were issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: some of the tiles on the pool wall were missing; there was no drinking water fountain; there was no life ring; the pool rules sign was not completely filled out; one of the "Shallow Water – No Diving Allowed" signs was deteriorated; the current pool operator of record information was not posted to the public; the main drain grates were not in place; and, the bound and numbered log book was not maintained on a daily basis.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of one thousand, three hundred sixty dollars (**\$1,360.00**). The Individual/Entity submitted a corrective action plan and corrected the deficiencies.

47) Order Type and Number: Consent Order 16-122-RW  
Order Date: September 27, 2016  
Individual/Entity: **Lakeview at Surfside Beach Homeowners Association, Inc.**  
Facility: Lakeview at Surfside Beach  
Location: 517 Lake Shore  
Surfside Beach, SC 29575  
Mailing Address: P.O. Box 14176  
Surfside Beach, SC 29575  
County: Horry

Previous Orders: None  
Permit/ID Number: 26-1387B  
Violations Cited: S.C. Code Ann. Regs. 61-51(J)

Summary: Lakeview at Surfside Beach Homeowners Association, Inc. (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On May 31, 2016, July 1, 2016, and July 25, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: the chlorine level was not within the acceptable range of water quality standards; the emergency notification device was not operating properly; the pool rules sign was not completely filled out; the cyanuric acid level was above the water quality standards acceptable limit; the current pool operator of record information was not posted to the public; the water level was too low; and, the facility address was not posted at the emergency notification device.

Action: The Individual/Entity is required to: submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of two thousand, forty dollars **(\$2,040.00)**.

48) Order Type and Number: Consent Order 16-123-RW  
Order Date: September 27, 2016  
Individual/Entity: **J & M Hospitality, Inc.**  
Facility: Super 8  
Location: 1591 Highway 17 North  
North Myrtle Beach, SC 29582  
Mailing Address: Same  
County: Horry  
Previous Orders: None  
Permit/ID Number: 26-L26-1  
Violations Cited: S.C. Code Ann. Regs. 61-51(J)

Summary: J & M Hospitality, Inc. (Individual/Entity) owns and is responsible for the proper operation and maintenance of a pool. On June 7, 2016, and July 6, 2016, the pool was inspected and a violation was issued for failure to properly operate and maintain. The Individual/Entity has violated the Public Swimming Pools Regulation as follows: the chlorine and pH levels were not within the acceptable range of water quality standards; and, the emergency notification device was not operational.

Action: The Individual/Entity is required to: keep the pool closed until the deficiencies have been corrected; submit a corrective action plan and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of six hundred eighty dollars **(\$680.00)**.



## Drinking Water Enforcement

49)     Order Type and Number:                     Consent Order 16-046-DW  
          Order Date:                                 September 13, 2016  
          Individual/Entity:                         **Caroline Investments, LLC**  
          Facility:                                     Caroline Inn and Suites  
          Location:                                    810 Hospitality Drive  
  Spartanburg, SC 29303  
  
          Mailing Address:                         Same  
          County:                                     Spartanburg  
          Previous Orders:                         None  
          Permit/ID Number:                     SC42136874  
          Violations Cited:                     S.C. Code Ann. Regs.  
  61-58.4.D(14)

Summary: Caroline Investments, LLC (Individual/Entity) owns the Caroline Inn and Suites (Site). On April 22, 2016, Department staff conducted an inspection at the Site and discovered that an irrigation well was connected to the piping within the building to supply water to the toilets and outside faucets. The Individual/Entity has violated the State Primary Drinking Water Regulations as follows: it installed a high hazard connection between a public water system distribution system and an irrigation well whereby unsafe water or other contamination materials may be discharged or drawn into the system.

Action: The Individual/Entity is required to: remove all distribution lines installed that connect the irrigation well to the building; submit a written request of the intended use of the irrigation well; and, pay a civil penalty in the amount of four thousand dollars **(\$4,000.00)**.

50)     Order Type and Number:                     Consent Order 16-047-DW  
          Order Date:                                 September 16, 2016  
          Individual/Entity:                         **Lake Pointe Self Storage, LLC**  
          Facility:                                     The Vault Self Storage  
          Location:                                    4180 Charlotte Highway  
  Lake Wylie, SC 29710  
  
          Mailing Address:                         1201-101 Carolina Place Drive  
  Fort Mill, SC 29708  
  
          County:                                     York  
          Previous Orders:                         None  
          Permit/ID Number:                     30786-WS  
          Violations Cited:                     S.C. Code Ann. Regs. 61-58.1.K(1)

Summary: Lake Pointe Self Storage, LLC (Individual/Entity) owns and is responsible for the proper construction, and operation of a public water system in accordance with Water Supply Construction Permit No. 30786-WS to serve The Vault Self Storage (Site). On May 26, 2016, the Site was inspected and it was determined

that the public water system had been placed into operation prior to obtaining written approval to operate from the Department. The Individual/Entity has violated the State Primary Drinking Water Regulations as follows: failure to obtain written approval to operate from the Department prior to placing a public water system into operation.

Action: The Individual/Entity is required to: pay a civil penalty in the amount of one thousand dollars (**\$1,000.00**). On August 29, 2016, the Department issued final approval to place the public water system into operation.

51) Order Type and Number: Consent Order 16-048-DW  
Order Date: September 21, 2016  
Individual/Entity: **R&R Deer Processing, Inc.**  
Facility: R&R Venison Specialties  
Location: 3965 State Road  
Ridgeville, SC 29472  
Mailing Address: Same  
County: Berkeley  
Previous Orders: None  
Permit/ID Number: 0830810  
Violations Cited: S.C. Code Ann. Regs. 61-58.17.K(1)

Summary: R&R Deer Processing, Inc. (Individual/Entity) owns and is responsible for the proper operation and maintenance of a public water system (PWS). On August 17, 2016, a violation was issued as a result of review of monitoring records. The Individual/Entity has violated the State Primary Drinking Water Regulations as follows: the PWS exceeded the maximum contaminant level (MCL) for E. coli.

Action: The Individual/Entity is required to: submit an investigative report to determine the causes of the MCL violation and a corrective action plan to include proposed steps to address those causes; and, pay a **stipulated penalty** in the amount of four thousand dollars (**\$4,000.00**) should any requirement of the Order not be met.

52) Order Type and Number: Consent Order 16-049-DW  
Order Date: September 23, 2016  
Individual/Entity: **Carolina Water Service, Inc.**  
Facility: CWS Rollingwood  
Location: 150 Foster Brothers Drive  
West Columbia, SC 29171  
Mailing Address: Same  
County: Lexington  
Previous Orders: None  
Permit/ID Number: 3250052

Violations Cited:

S.C. Code Ann. Regs. 61-58.5.P(2)(b)

Summary: Carolina Water Service, Inc. (Individual/Entity) owns and is responsible for the proper operation and maintenance of a public water system (PWS). On June 29, 2016, a violation was issued as a result of review of monitoring records. The Individual/Entity has violated the State Primary Drinking Water Regulations as follows: the PWS exceeded the maximum contaminant level (MCL) for haloacetic acids five (HAA5).

Action: The Individual/Entity is required to: submit a corrective action plan to include proposed steps to address the MCL violation; and, pay a **stipulated penalty** in the amount of four thousand dollars (**\$4,000.00**) should any requirement of the Order not be met.

53) Order Type and Number: Consent Order 16-050-DW  
Order Date: September 23, 2016  
Individual/Entity: **Carolina Water Service, Inc.**  
Facility: CWS I-20  
Location: 150 Foster Brothers Drive  
West Columbia, SC 29171  
Mailing Address: Same  
County: Lexington  
Previous Orders: None  
Permit/ID Number: 3250012  
Violations Cited: S.C. Code Ann. Regs. 61-58.5.P(2)(b)

Summary: Carolina Water Service, Inc. (Individual/Entity) owns and is responsible for the proper operation and maintenance of a public water system (PWS). On June 29, 2016, a violation was issued as a result of review of monitoring records. The Individual/Entity has violated the State Primary Drinking Water Regulations as follows: the PWS exceeded the maximum contaminant level (MCL) for haloacetic acids five (HAA5).

Action: The Individual/Entity is required to: submit a corrective action plan to include proposed steps to address the MCL violation; and, pay a **stipulated penalty** in the amount of four thousand dollars (**\$4,000.00**) should any requirement of the Order not be met.

54) Order Type and Number: Consent Order 16-051-DW  
Order Date: September 23, 2016  
Individual/Entity: **Carolina Water Service, Inc.**  
Facility: Charleswood Subdivision  
Location: 101 Charleswood Drive  
Columbia, SC 29223  
Mailing Address: 150 Foster Brothers Drive

County: West Columbia, SC 29172  
Previous Orders: Richland  
Permit/ID Number: None  
Violations Cited: 4050008  
S.C. Code Ann. Regs. 61-58.5.H(2)

Summary: Carolina Water Service, Inc. (Individual/Entity) owns and is responsible for the proper operation and maintenance of a public water system (PWS). On July 27, 2016, a violation was issued as a result of review of monitoring records. The Individual/Entity has violated the State Primary Drinking Water Regulations as follows: the PWS exceeded the maximum contaminant level (MCL) for combined radium 226/228.

Action: The Individual/Entity is required to: submit a corrective action plan to include proposed steps to address the MCL violation; and, pay a **stipulated penalty** in the amount of four thousand dollars (**\$4,000.00**) should any requirement of the Order not be met.

### **Water Pollution Enforcement**

55) Order Type and Number: Consent Order 16-027-W  
Order Date: September 8, 2016  
Individual/Entity: **Carolina Development Services, LLC**  
Facility: Fox Ridge Phase III  
Location: Three quarters of a mile south of the Intersection of SC Highway 60 and Possum Hollow Road  
Mailing Address: 2649 Breckenridge Road, Suite 107  
Monroe, NC 28110  
County: Lancaster  
Previous Orders: None  
Permit/ID Number: SCR10U376  
Violations Cited: Pollution Control Act, S.C. Code Ann. § 48-1-90(A)(1)(Supp. 2015), Water Pollution Control Permits S.C. Code Ann. Regs. 61-9.122.41(a) and (e) (Supp. 2011), Water Classifications and Standards S.C. Code Ann. Regs. 61-68(E)(5)(d)(Supp. 2015).

Summary: Carolina Development Services, LLC (Individual/Entity) owns and is responsible for land disturbing activity located in Lancaster County, South Carolina. On July 23, 2015, November 17, 2015, and January 27, 2016, the Department forwarded inspection reports to the Individual/Entity, notifying of deficiencies and unsatisfactory conditions at the Site. The Individual/Entity has violated the Pollution Control Act, Water Classification and Standards Regulations, and Water Pollution Control Permits Regulation as follows: failed to comply with the conditions of its

National Pollutant Discharge Elimination System (NPDES) permit, discharged sediment into the environment, including waters of the State, in a manner other than in compliance with its permit, and failed to keep waters of the State free from sediment that interferes with classified and/or existing water uses, or which is harmful to aquatic life.

Action: The Individual/Entity is required to: correct the deficiencies and bring the Site into compliance with the conditions and requirements of its NPDES permit and the approved Storm Water Pollution Prevention Plan (SWPPP); submit engineer certification that all storm water and sediment control devices are installed and functioning properly; and, pay a civil penalty in the amount sixty-nine thousand, seven hundred dollars (**\$69,700.00**) in five (5) monthly installments.

56) Order Type and Number: Consent Order 16-028-W  
Order Date: September 8, 2016  
Individual/Entity: **Fontaine Construction of Anderson**  
Facility: McAlister Mine  
Location: 288 Westinghouse Road  
Pendleton, SC 29670  
Mailing Address: 7007 Highway 29 N  
Pelzer, SC 29669  
County: Anderson  
Previous Orders: None  
Permit/ID Number: SCG731245  
Violations Cited: Pollution Control Act, S.C. Code Ann. § 48-1-90(A)(1) and 110(d)(Supp. 2015), Water Pollution Control Permits S.C. Code Ann. Regs. 24 S.C. Code Ann. Regs. 61-9.122.41(a) and (e) (2011).

Summary: Fontaine Construction of Anderson (Individual/Entity) owns and is responsible for the proper operation and maintenance of the McAlister Mine, located in Anderson County, South Carolina. On October 23, 2015, and April 20, 2016, the Department forwarded inspection reports to the Individual/Entity, notifying of deficiencies and unsatisfactory conditions at the Site. The Individual/Entity has violated the Pollution Control Act and Water Pollution Control Permits Regulation as follows: failed to comply with the conditions of its National Pollutant Discharge Elimination System (NPDES) permit and allowed sediment to discharge into the environment, including waters of the state, in a manner other than in compliance with a permit issued by the Department.

Action: The Individual/Entity is required to: correct the deficiencies and bring the Site into compliance with the conditions and requirements of the NPDES permit; conduct weekly inspections of the Site by a Certified Erosion Prevention and Sediment Control Inspector; submit the weekly inspection reports to the Department; submit a Storm Water Pollution Prevention Plan prepared by a South Carolina Registered Professional Engineer, to include storm water, erosion and sediment controls, and best management practices to be implemented and

maintained at the Site until reclamation of the Site is complete and approved by the Department; submit engineer certification that all storm water and sediment control devices are installed and functioning properly; and, pay a civil penalty in the amount fifteen thousand, seven hundred dollars (**\$15,700.00**) in three (3) monthly installments.

57) Order Type and Number: Consent Order 16-029-W  
Order Date: September 13, 2016  
Individual/Entity: **Chemtrade Performance  
Chemicals US, LLC**  
Facility: Chemtrade Performance  
Chemicals WWTP  
Location: 3507 Leeds Rd  
Carlisle, SC 29031  
Mailing Address: 3507 Leeds Rd  
Carlisle, SC 29031  
County: Kershaw  
Previous Orders: None  
Permit/ID Number: SC0022756  
Violations Cited: Pollution Control Act, S.C. Code Ann. §  
48-1-110(d) (Supp. 2015); Water Pollution Control Permits, 3 S.C. Code Ann.  
Regs. 61-9.122.41(a) and (l)(4)(Supp. 2015).

Summary: Chemtrade Performance Chemicals US, LLC (Individual/Entity) owns and is responsible for the proper operation and maintenance of a wastewater treatment plant (WWTP) located in Chester County, South Carolina. On July 14, 2016, a Notice of Violation was issued as a result of discharge monitoring reports submitted to the Department. The Individual/Entity has violated the Pollution Control Act and Water Pollution Control Permits Regulation as follows: failed to comply with the monitoring requirements for Acute Toxicity in its National Pollutant Discharge Elimination permit.

Action: The Individual/Entity is required to: submit a corrective action plan to address the deficiencies; and, pay a civil penalty in the amount of two thousand, eight hundred twenty-five dollars (**\$2,825.00**).

58) Order Type and Number: Consent Order 16-030-W  
Order Date: September 21, 2016  
Individual/Entity: **Saluda County Water & Sewer  
Authority**  
Facility: Celebrations Church Fellowship  
Location: 106 N. Jennings St.  
Saluda, SC 29138  
Mailing Address: 113 E. Church St.  
Saluda, SC 29138

County: Saluda  
Previous Orders: None  
Permit/ID Number: Construction Permit #38795-WW  
Violations Cited: Pollution Control Act, S.C Code Ann § 48-1-110(a)(3) (Supp. 2015), Standards for Wastewater Facility Construction, 24 S.C. Code Ann. Regs. 61-67.100(E)(7) (Supp. 2015).

Summary: Saluda County Water & Sewer Authority (Individual/Entity) owns and is responsible for construction of a wastewater system. On May 12, 2015, and July 21, 2016, Notices of Violation were issued as a result of the Individual/Entity installing and operating a wastewater system without a Final Approval to Operate issued by the Department. The Individual/Entity has violated the Pollution Control Act and Standards for Wastewater Facility Construction Regulation as follows: failed to obtain approval prior to placing a wastewater system into operation.

Action: The Individual/Entity is required to: submit a corrective action plan to address the deficiencies and prevent recurrence of similar violations; and, pay a civil penalty in the amount of one thousand dollars **(\$1,000.00)**.

59) Order Type and Number: Consent Order 16-031-W  
Order Date: September 23, 2016  
Individual/Entity: **Dorchester County Water & Sewer**  
Facility: Lower Dorchester Wastewater  
Treatment Plant  
Location: 201 Johnston St.  
Saint George, SC 29477  
Mailing Address: 235 Deming Way  
Summerville, SC 29483  
County: Dorchester  
Previous Orders: None  
Permit/ID Number: SC0038822  
Violations Cited: Pollution Control Act, S.C Code Ann § 48-1-110 (Supp. 2015), Water Pollution Control Permits, 3 S.C. Code Ann. Regs. 61-9.122.41 (2011), and National Pollutant Discharge Elimination System Permit Number SC0028822.

Summary: Dorchester County Water & Sewer (Individual/Entity) owns and is responsible for the proper operation and maintenance of the Lower Dorchester Wastewater Treatment Plant in Dorchester County, South Carolina. On June 9, 2016, a Notice of Violation was issued as a result of discharge monitoring reports received by the Department. The Individual/Entity has violated the Pollution Control Act, Water Pollution Control Permits Regulation and National Pollutant Discharge Elimination System (NPDES) Permit SC0038822 as follows: failed to comply with effluent discharge limits of its NPDES permit for NH3-N and E. coli.

Action: The Individual/Entity is required to: submit a corrective action plan (CAP) and schedule of implementation to address the deficiencies; and, pay a civil penalty in the amount of four thousand, eight hundred dollars (**\$4,800.00**).

60) Order Type and Number: Consent Order 16-032-W  
Order Date: September 30, 2016  
Individual/Entity: **Seabrook Island Utility Commission**  
Facility: Town of Seabrook WWTP  
Location: Off River Road on Johns Island  
Seabrook Island, SC 29455  
Mailing Address: 2902A Seabrook Island Rd  
Johns Island, SC 29455  
County: Charleston  
Previous Orders: None  
Permit/ID Number: ND0063347  
Violations Cited: Pollution Control Act, S.C Code Ann § 48-1-110 (d) (Supp. 2015), Water Pollution Control Permits, 3 S.C. Code Ann. Regs. 61-9.122.41 (a) (2011), and Land Application Permit ND0063347.

Summary: Seabrook Island Utility Commission (Individual/Entity) owns and is responsible for the proper operation and maintenance of the Town of Seabrook Wastewater Treatment Plant in Charleston County, South Carolina. On May 2, 2016, a Notice of Violation was issued as a result of discharge monitoring reports received by the Department. The Individual/Entity has violated the Pollution Control Act, Water Pollution Control Permits Regulation and State Land Application Permit ND0063347 (ND Permit) as follows: failed to comply with effluent discharge limits of its ND Permit for Fecal Coliform.

Action: The Individual/Entity is required to: submit a corrective action plan (CAP) to address the deficiencies; and, pay a civil penalty in the amount of three thousand, three hundred and sixty dollars (**\$3,360.00**).

61) Order Type and Number: Consent Order 16-033-W  
Order Date: September 30, 2016  
Individual/Entity: **Mark III Properties**  
Facility: Rainwater Subdivision  
Location: Site off of Highway 290  
Duncan, SC  
Mailing Address: 726 Camelot Drive, Ste A  
Spartanburg, SC 29301  
County: Spartanburg  
Previous Orders: None  
Permit/ID Number: SCR10V222



Violations Cited: Pollution Control Act, S.C. Code Ann. § 48-1-90(A)(1) and 110(d)(Supp. 2015), Water Pollution Control Permits S.C. Code Ann. Regs. 24 S.C. Code Ann. Regs. 61-9.122.21(a) and 122.41 (a) (2011).

Summary: Mark III Properties (Individual/Entity) is responsible for land disturbing activity in Spartanburg County, South Carolina. On March 16, 2016, and April 20, 2016, the Department forwarded inspection reports to the Individual/Entity, notifying of deficiencies and unsatisfactory conditions at the Site. The Individual/Entity has violated the Pollution Control Act and the Water Pollution Control Permits Regulation as follows: failed to comply with the conditions of its National Pollutant Discharge Elimination System (NPDES) permit and allowed sediment to discharge into the environment, including waters of the state, in a manner other than in compliance with a permit issued by the Department.

Action: The Individual/Entity is required to: submit engineer certification that all storm water and sediment control devices are installed and functioning properly; properly monitor and maintain all sediment control devices until completion of development at the Site; and, pay a civil penalty in the amount of six thousand, four hundred and sixty dollars (**\$6,460.00**).

#### **BUREAU OF ENVIRONMENTAL HEALTH SERVICES**

62)	<u>Order Type and Number:</u>	Consent Order 2016-206-08-017
	<u>Order Date:</u>	September 6, 2016
	<u>Individual/Entity:</u>	<b>China Kitchen</b>
	<u>Facility:</u>	China Kitchen
	<u>Location:</u>	386-D Mark Cummings Rd, Ste. 104 Hardeeville, SC 29927
	<u>Mailing Address:</u>	Same
	<u>County:</u>	Jasper
	<u>Previous Orders:</u>	None
	<u>Permit Number:</u>	27-206-00555
	<u>Violations Cited:</u>	S.C. Code Ann. Regs. 61-25

Summary: China Kitchen (Individual/Entity) is a restaurant located in Hardeeville, South Carolina. The Department conducted inspections on February 26, 2015, March 28, 2016, April 7, 2016, April 18, 2016, and April 28, 2016. The Individual/Entity violated the South Carolina Retail Food Establishment Regulation as follows: failed to store foods in a manner to prevent cross contamination; failed to store foods and clean utensils in a clean, dry location, at least 6 inches off the floor; and failed to ensure equipment is sealed to adjoining equipment or walls when exposed to spillage or seepage.

Action: The Individual/Entity is required to: operate and maintain the facility in accordance with the requirements of all applicable regulations, including S.C. Regs. 61-25; and, pay a civil penalty in the amount of one thousand, five hundred dollars **(\$1,500.00)**.

63) Order Type and Number: Consent Order 2016-206-03-032  
Order Date: September 9, 2016  
Individual/Entity: **Sporting News Grill**  
Facility: Sporting News Grill  
Location: 110 McSwain Drive  
West Columbia, SC 29169  
Mailing Address: Same  
County: Lexington  
Previous Orders: None  
Permit Number: 32-206-05707  
Violations Cited: S.C. Code Ann. Regs. 61-25

Summary: Sporting News Grill (Individual/Entity) is a restaurant located in West Columbia, South Carolina. The Department conducted inspections on March 25, 2015, March 10, 2016, and March 18, 2016. The Individual/Entity violated the South Carolina Retail Food Establishment Regulation as follows: failed to store foods in a manner to prevent cross contamination.

Action: The Individual/Entity is required to: operate and maintain the facility in accordance with the requirements of all applicable regulations, including S.C. Regs. 61-25; and, pay a civil penalty in the amount of one thousand, two hundred dollars **(\$1,200.00)**.

64) Order Type and Number: Consent Order 2015-206-03-094  
Order Date: September 9, 2016  
Individual/Entity: **China Taste**  
Facility: China Taste  
Location: 1132 Mack Street  
Gaston, SC 29053  
Mailing Address: Same  
County: Lexington  
Previous Orders: None  
Permit Number: 32-206-04239  
Violations Cited: S.C. Code Ann. Regs. 61-25

Summary: China Taste (Individual/Entity) operates a restaurant located in Gaston, South Carolina. The Department conducted inspections on June 25, 2015, June 30, 2015, and June 6, 2016. The Individual/Entity violated the South Carolina Retail Food Establishment Regulation as follows: failed to maintain proper holding temperatures of time/temperature control for safety foods.

Action: The Individual/Entity is required to: operate and maintain the facility in accordance with the requirements of all applicable regulations, including S.C. Regs. 61-25; and, pay a civil penalty in the amount of one thousand, two hundred dollars **(\$1,200.00)**.

65) Order Type and Number: Consent Order 2016-206-03-027  
Order Date: September 9, 2016  
Individual/Entity: **Bob Evans #100**  
Facility: Bob Evans #100  
Location: 520 John Ross Parkway  
Rock Hill, SC 29703  
Mailing Address: 8111 Smith Mill Road  
New Albany, OH 43054  
County: York  
Previous Orders: None  
Permit Number: 46-206-01645  
Violations Cited: S.C. Code Ann. Regs. 61-25

Summary: Bob Evans Farms #100 (Individual/Entity) is a restaurant located in Rock Hill, South Carolina. The Department conducted inspections on April 13, 2016, and July 28, 2016. The Individual/Entity violated the South Carolina Retail Food Establishment Regulation as follows: failed to maintain proper holding temperatures of time/temperature control for safety foods.

Action: The Individual/Entity is required to: operate and maintain the facility in accordance with the requirements of all applicable regulations, including S.C. Regs. 61-25; and, pay a civil penalty in the amount of eight hundred dollars **(\$800.00)**.

66) Order Type and Number: Consent Order 2016-206-03-021  
Order Date: September 9, 2016  
Individual/Entity: **Hamm's Hawg Heaven**  
Facility: Hamm's Hawg Heaven  
Location: 11375 CR Koon Highway  
Prosperity, SC 29127  
Mailing Address: P.O. Box 919  
Prosperity, SC 29127  
County: Newberry  
Previous Orders: 2015-206-03-055 (\$800.00)  
Permit Number: 36-206-01008  
Violations Cited: S.C. Code Ann. Regs. 61-25

Summary: Hamm's Hawg Heaven (Individual/Entity) is a restaurant located in Prosperity, South Carolina. The Department conducted an inspection on March 24, 2016. The Individual/Entity violated the South Carolina Retail Food Establishment

Regulation as follows: failed to maintain proper holding temperatures of time/temperature control for safety foods.

Action: The Individual/Entity is required to: operate and maintain the facility in accordance with the requirements of all applicable regulations, including S.C. Regs. 61-25; and, pay a civil penalty in the amount of six hundred dollars **(\$600.00)**.

67) Order Type and Number: Consent Order 2016-206-03-035  
Order Date: September 9, 2016  
Individual/Entity: **San Jose**  
Facility: San Jose  
Location: 115 Northpoint Drive  
Lexington, SC 29072  
Mailing Address: Same  
County: Lexington  
Previous Orders: None  
Permit Number: 32-206-05350  
Violations Cited: S.C. Code Ann. Regs. 61-25

Summary: San Jose (Individual/Entity) is a restaurant located in Lexington, South Carolina. The Department conducted inspections on May 1, 2015, and April 20, 2016. The Individual/Entity violated the South Carolina Retail Food Establishment Regulation as follows: failed to ensure employees wash hands after engaging in activities that contaminate their hands.

Action: The Individual/Entity is required to: operate and maintain the facility in accordance with the requirements of all applicable regulations, including S.C. Regs. 61-25; and, pay a civil penalty in the amount of eight hundred dollars **(\$800.00)**.

68) Order Type and Number: Consent Order 2016-206-01-021  
Order Date: September 9, 2016  
Individual/Entity: **George's Drive-In**  
Facility: George's Drive-In  
Location: 1301 S. Murray Avenue  
Anderson, SC 29624  
Mailing Address: Same  
County: Anderson  
Previous Orders: None  
Permit Number: 04-206-01687  
Violations Cited: S.C. Code Ann. Regs. 61-25

Summary: George's Drive-In (Individual/Entity) is a restaurant located in Anderson, South Carolina. The Department conducted inspections on March 28, 2016, and April 7, 2016. The Individual/Entity violated the South Carolina Retail Food

Establishment Regulation as follows: failed to maintain proper holding temperatures of time/temperature control for safety foods.

Action: The Individual/Entity is required to: operate and maintain the facility in accordance with the requirements of all applicable regulations, including S.C. Regs. 61-25; and, pay a civil penalty in the amount of eight hundred dollars **(\$800.00)**.

69) Order Type and Number: Consent Order 2016-206-01-020  
Order Date: September 12, 2016  
Individual/Entity: **Ronnie's Café**  
Facility: Ronnie's Cafe  
Location: 2101 Centerville Road  
Anderson, SC 29625  
Mailing Address: Same  
County: Anderson  
Previous Orders: None  
Permit Number: 04-206-04141  
Violations Cited: S.C. Code Ann. Regs. 61-25

Summary: Ronnie's Cafe (Individual/Entity) is a restaurant located in Anderson, South Carolina. The Department conducted inspections on October 23, 2015, and March 30, 2016. The Individual/Entity violated the South Carolina Retail Food Establishment Regulation as follows: failed to maintain proper sanitization concentration for the warewashing (dish) machine.

Action: The Individual/Entity is required to: operate and maintain the facility in accordance with the requirements of all applicable regulations, including S.C. Regs. 61-25; and, pay a civil penalty in the amount of eight hundred dollars **(\$800.00)**.

70) Order Type and Number: Consent Order 2016-206-03-026  
Order Date: September 13, 2016  
Individual/Entity: **Gus' House of Pizza**  
Facility: Gus' House of Pizza  
Location: 605 South Main Street  
Lancaster, SC 29720  
Mailing Address: Same  
County: Lancaster  
Previous Orders: 2013-206-04-002  
Permit Number: 29-206-00743  
Violations Cited: S.C. Code Ann. Regs. 61-25

Summary: Gus' House of Pizza (Individual/Entity) is a restaurant located in Lancaster, South Carolina. The Department conducted inspections on April 7, 2015, April 14, 2015, and April 5, 2016. The Individual/Entity violated the South Carolina

Retail Food Establishment Regulation as follows: failed to maintain proper holding temperatures of time/temperature control for safety foods.

Action: The Individual/Entity is required to: operate and maintain the facility in accordance with the requirements of all applicable regulations, including S.C. Regs. 61-25; and, pay a civil penalty in the amount of one thousand, two hundred dollars **(\$1,200.00)**.

71) Order Type and Number: Consent Order 2016-206-03-019  
Order Date: September 13, 2016  
Individual/Entity: **Crescent Moon**  
Facility: Crescent Moon  
Location: 2361-A Augusta Highway  
Lexington, SC 29072  
Mailing Address: Same  
County: Lexington  
Previous Orders: 2015-206-03-068  
Permit Number: 32-206-06119  
Violations Cited: S.C. Code Ann. Regs. 61-25

Summary: Crescent Moon (Individual/Entity) is a restaurant located in Lexington, South Carolina. The Department conducted inspections on May 27, 2015, and March 22, 2016. The Individual/Entity violated the South Carolina Retail Food Establishment Regulation as follows: failed to ensure poisonous or toxic chemicals were stored away from food and food contact surfaces.

Action: The Individual/Entity is required to: operate and maintain the facility in accordance with the requirements of all applicable regulations, including S.C. Regs. 61-25; and, pay a civil penalty in the amount of eight hundred dollars **(\$800.00)**.

72) Order Type and Number: Consent Order 2016-206-03-024  
Order Date: September 15, 2016  
Individual/Entity: **Carolina Wings of Blythewood**  
Facility: Carolina Wings of Blythewood  
Location: 240 Blythewood Road  
Blythewood, SC 29016  
Mailing Address: P.O. Box 1002  
Blythewood, SC 29016  
County: Richland  
Previous Orders: 2015-206-03-052 (\$800.00)  
Permit Number: 40-206-07212  
Violations Cited: S.C. Code Ann. Regs. 61-25

Summary: Carolina Wings of Blythewood (Individual/Entity) is a restaurant located in Columbia, South Carolina. The Department conducted inspections on

September 3, 2015, and September 4, 2015. The Individual/Entity violated the South Carolina Retail Food Establishment Regulation as follows: failed to maintain proper holding temperatures of time/temperature control for safety foods.

Action: The Individual/Entity is required to: operate and maintain the facility in accordance with the requirements of all applicable regulations, including S.C. Regs. 61-25; and, pay a civil penalty in the amount of eight hundred dollars **(\$800.00)**.

73) Order Type and Number: Consent Order 2016-206-03-038  
Order Date: September 15, 2016  
Individual/Entity: **El Poblano Mexican Restaurant**  
Facility: El Poblano Mexican Restaurant  
Location: 2371 Dutch Fork Road  
Chapin, SC 29036  
Mailing Address: Same  
County: Richland  
Previous Orders: None  
Permit Number: 40-206-06403  
Violations Cited: S.C. Code Ann. Regs. 61-25

Summary: El Poblano Mexican Restaurant (Individual/Entity) is a restaurant located in Chapin, South Carolina. The Department conducted inspections on April 28, 2016, and August 17, 2016. The Individual/Entity violated the South Carolina Retail Food Establishment Regulation as follows: failed to store foods in a manner to prevent cross contamination.

Action: The Individual/Entity is required to: operate and maintain the facility in accordance with the requirements of all applicable regulations, including S.C. Regs. 61-25; and, pay a civil penalty in the amount of eight hundred dollars **(\$800.00)**.

74) Order Type and Number: Consent Order 2016-206-03-034  
Order Date: September 15, 2016  
Individual/Entity: **Richland Healthy Cuisine**  
Facility: Richland Healthy Cuisine  
Location: 9 Medical Park, Suite 120  
Columbia, SC 29203  
Mailing Address: Same  
County: Richland  
Previous Orders: None  
Permit Number: 40-206-03838  
Violations Cited: S.C. Code Ann. Regs. 61-25

Summary: Richland Healthy Cuisine (Individual/Entity) is a restaurant located in Columbia, South Carolina. The Department conducted inspections on March 8, 2016, and May 11, 2016. The Individual/Entity violated the South Carolina Retail

Food Establishment Regulation as follows: failed to maintain proper holding temperatures of time/temperature control for safety foods.

Action: The Individual/Entity is required to: operate and maintain the facility in accordance with the requirements of all applicable regulations, including S.C. Regs. 61-25; and, pay a civil penalty in the amount of eight hundred dollars **(\$800.00)**.

75) Order Type and Number: Consent Order 2016-206-03-029  
Order Date: September 26, 2016  
Individual/Entity: **Waffle House #1318**  
Facility: Waffle House #1318  
Location: 655 Columbia Avenue  
Chapin, SC 29036  
Mailing Address: P.O. Box 6450  
Norcross, GA 30091  
County: Lexington  
Previous Orders: 2015-206-03-78  
Permit Number: 32-206-02740  
Violations Cited: S.C. Code Ann. Regs. 61-25

Summary: Waffle House #1318 (Individual/Entity) is a restaurant located in Chapin, South Carolina. The Department conducted inspections on March 29, 2016, and May 12, 2016. The Individual/Entity violated the South Carolina Retail Food Establishment Regulation as follows: failed to maintain proper holding temperatures of time/temperature control for safety foods; and failed to maintain food contact surfaces clean to sight and touch.

Action: The Individual/Entity is required to: operate and maintain the facility in accordance with the requirements of all applicable regulations, including S.C. Regs. 61-25; and, pay a civil penalty in the amount of eight hundred dollars **(\$800.00)**.

76) Order Type and Number: Consent Order 2016-206-08-019  
Order Date: September 26, 2016  
Individual/Entity: **Waffle House #820**  
Facility: Waffle House #820  
Location: 503 East Main Street  
Ridgeland, SC 29936  
Mailing Address: P.O. Box 6450  
Norcross, GA 30091  
County: Jasper  
Previous Orders: None  
Permit Number: 27-206-00246  
Violations Cited: S.C. Code Ann. Regs. 61-25



Summary: Waffle House #820 (Individual/Entity) is a restaurant located in Ridgeland, South Carolina. The Department conducted inspections on May 24, 2016, and May 27, 2016. The Individual/Entity violated the South Carolina Retail Food Establishment Regulation as follows: failed to maintain proper holding temperatures of time/temperature control for safety foods.

Action: The Individual/Entity is required to: operate and maintain the facility in accordance with the requirements of all applicable regulations, including S.C. Regs. 61-25; and, pay a civil penalty in the amount of eight hundred dollars (**\$800.00**).

77) Order Type and Number: Consent Order 2016-206-04-001  
Order Date: September 26, 2016  
Individual/Entity: **Waffle House #1079**  
Facility: Waffle House #1079  
Location: 1350 Broad Street  
Sumter, SC 29150  
Mailing Address: P.O. Box 6450  
Norcross, GA 30091  
County: Sumter  
Previous Orders: None  
Permit Number: 43-206-00377  
Violations Cited: S.C. Code Ann. Regs. 61-25

Summary: Waffle House #1079 (Individual/Entity) is a restaurant located in Sumter, South Carolina. The Department conducted inspections on September 15, 2015, and April 27, 2016. The Individual/Entity violated the South Carolina Retail Food Establishment Regulation as follows: failed to maintain proper holding temperatures of time/temperature control for safety foods.

Action: The Individual/Entity is required to: operate and maintain the facility in accordance with the requirements of all applicable regulations, including S.C. Regs. 61-25; and, pay a civil penalty in the amount of eight hundred dollars (**\$800.00**).

78) Order Type and Number: Consent Order 2016-206-04-017  
Order Date: September 26, 2016  
Individual/Entity: **Waffle House #1268**  
Facility: Waffle House #1268  
Location: 1041 Broad Street  
Sumter, SC 29150  
Mailing Address: P.O. Box 6450  
Norcross, GA 30091  
County: Sumter  
Previous Orders: None  
Permit Number: 43-206-00377  
Violations Cited: S.C. Code Ann. Regs. 61-25

Summary: Waffle House #1268 (Individual/Entity) is a restaurant located in Sumter, South Carolina. The Department conducted inspections on April 21, 2015, and April 12, 2016. The Individual/Entity violated the South Carolina Retail Food Establishment Regulation as follows: failed to maintain proper holding temperatures of time/temperature control for safety foods.

Action: The Individual/Entity is required to: operate and maintain the facility in accordance with the requirements of all applicable regulations, including S.C. Regs. 61-25; and, pay a civil penalty in the amount of eight hundred dollars (**\$800.00**).

79) Order Type and Number: Consent Order 2016-206-01-018  
Order Date: September 26, 2016  
Individual/Entity: **Waffle House #426**  
Facility: Waffle House #426  
Location: 4620 Clemson Blvd.  
Anderson, SC 29622  
Mailing Address: P.O. Box 6450  
Norcross, GA 30091  
County: Anderson  
Previous Orders: 2015-206-01-020  
Permit Number: 04-206-01431  
Violations Cited: S.C. Code Ann. Regs. 61-25

Summary: Waffle House #426 (Individual/Entity) is a restaurant located in Anderson, South Carolina. The Department conducted inspections on June 24, 2015, and April 25, 2016. The Individual/Entity violated the South Carolina Retail Food Establishment Regulation as follows: failed to ensure that when time without temperature control is used as a public health control, the food in unmarked containers or packages shall be discarded after a maximum of four (4) hours.

Action: The Individual/Entity is required to: operate and maintain the facility in accordance with the requirements of all applicable regulations, including S.C. Regs. 61-25; and, pay a civil penalty in the amount of eight hundred dollars (**\$800.00**).

80) Order Type and Number: Consent Order 2016-206-03-030  
Order Date: September 26, 2016  
Individual/Entity: **Waffle House #1828**  
Facility: Waffle House #1828  
Location: 2195 Highway 773  
Prosperity, SC 29127  
Mailing Address: P.O. Box 6450  
Norcross, GA 30091  
County: Newberry  
Previous Orders: None  
Permit Number: 36-206-01197

Violations Cited:

S.C. Code Ann. Regs. 61-25

Summary: Waffle House #1828 (Individual/Entity) is a restaurant located in Prosperity, South Carolina. The Department conducted inspections on July 23, 2015, and June 6, 2016. The Individual/Entity violated the South Carolina Retail Food Establishment Regulation as follows: failed to maintain 180°F minimum final rinse temperature for sanitization at the mechanical warewashing (dish) machine.

Action: The Individual/Entity is required to: operate and maintain the facility in accordance with the requirements of all applicable regulations, including S.C. Regs. 61-25; and, pay a civil penalty in the amount of eight hundred dollars (**\$800.00**).

81) Order Type and Number: Consent Order 2016-206-01-019  
Order Date: September 26, 2016  
Individual/Entity: **Waffle House #1823**  
Facility: Waffle House #1823  
Location: 2 Justice Lane  
Anderson, SC 29621  
Mailing Address: P.O. Box 6450  
Norcross, GA 30091  
County: Anderson  
Previous Orders: 2015-206-01-020  
Permit Number: 04-206-01431  
Violations Cited: S.C. Code Ann. Regs. 61-25

Summary: Waffle House #1823 (Individual/Entity) is a restaurant located in Anderson, South Carolina. The Department conducted inspections on October 22, 2015, and May 23, 2016. The Individual/Entity violated the South Carolina Retail Food Establishment Regulation as follows: failed to maintain proper holding temperatures of time/temperature control for safety foods.

Action: The Individual/Entity is required to: operate and maintain the facility in accordance with the requirements of all applicable regulations, including S.C. Regs. 61-25; and, pay a civil penalty in the amount of eight hundred dollars (**\$800.00**).

82) Order Type and Number: Consent Order 2016-206-02-013  
Order Date: September 26, 2016  
Individual/Entity: **Waffle House #1878**  
Facility: Waffle House #1878  
Location: 7425 Augusta Road  
Greenville, SC 29773  
Mailing Address: P.O. Box 6450  
Norcross, GA 30091  
County: Greenville  
Previous Orders: None

Permit Number: 23-206-09985  
Violations Cited: S.C. Code Ann. Regs. 61-25

Summary: Waffle House #1878 (Individual/Entity) is a restaurant located in Greenville, South Carolina. The Department conducted inspections on January 21, 2015, and January 7, 2016. The Individual/Entity violated the South Carolina Retail Food Establishment Regulation as follows: failed to store poisonous or toxic material in a manner that prevents cross contamination; and failed to ensure equipment such as beverage dispensing nozzles were cleaned at a frequency to preclude an accumulation of soil or mold.

Action: The Individual/Entity is required to: operate and maintain the facility in accordance with the requirements of all applicable regulations, including S.C. Regs. 61-25; and, pay a civil penalty in the amount of eight hundred dollars **(\$800.00)**.

83) Order Type and Number: Consent Order 2014-206-03-143  
Order Date: September 26, 2016  
Individual/Entity: **Food Gallery**  
Facility: Food Gallery  
Location: 3702 River Drive  
Columbia, SC 29201  
Mailing Address: Same  
County: Richland  
Previous Orders: None  
Permit Number: 40-206-04749  
Violations Cited: S.C. Code Ann. Regs. 61-25

Summary: Food Gallery (Individual/Entity) is a restaurant located in Columbia, South Carolina. The Department conducted inspections on July 16, 2015, July 21, 2015, and August 7, 2015. The Individual/Entity violated the South Carolina Retail Food Establishment Regulation as follows: failed to maintain proper holding temperatures of time/temperature control for safety foods.

Action: The Individual/Entity is required to: operate and maintain the facility in accordance with the requirements of all applicable regulations, including S.C. Regs. 61-25; and, pay a civil penalty in the amount of one thousand, two hundred dollars **(\$1,200.00)**.

84) Order Type and Number: Consent Order 2016-206-01-022  
Order Date: September 26, 2016  
Individual/Entity: **El Patron II**  
Facility: El Patron II  
Location: 186 Station Drive  
Anderson, SC 29621  
Mailing Address: Same

County: Anderson  
Previous Orders: None  
Permit Number: 04-206-03328  
Violations Cited: S.C. Code Ann. Regs. 61-25

Summary: El Patron II (Individual/Entity) is a restaurant located in Anderson, South Carolina. The Department conducted inspections on September 1, 2015, and April 5, 2016. The Individual/Entity violated the South Carolina Retail Food Establishment Regulation as follows: failed to maintain proper holding temperatures of time/temperature control for safety foods; and, failed to ensure proper sanitization concentrations levels at the mechanical warewashing (dish) machine.

Action: The Individual/Entity is required to: operate and maintain the facility in accordance with the requirements of all applicable regulations, including S.C. Regs. 61-25; and, pay a civil penalty in the amount of eight hundred dollars **(\$800.00)**.

85) Order Type and Number: Consent Order 2016-206-06-015  
Order Date: September 26, 2016  
Individual/Entity: **Johnny Rockets**  
Facility: Johnny Rockets  
Location: 1216 Celebrity Circle  
Myrtle Beach, SC 29572  
Mailing Address: P.O. Box 70339  
Myrtle Beach, SC 29572  
County: Horry  
Previous Orders: None  
Permit Number: 26-206-06857  
Violations Cited: S.C. Code Ann. Regs. 61-25

Summary: Johnny Rockets (Individual/Entity) is a restaurant located in Myrtle Beach, South Carolina. The Department conducted inspections on May 18, 2015, and February 2, 2016. The Individual/Entity violated the South Carolina Retail Food Establishment Regulation as follows: failed to maintain proper holding temperatures of time/temperature control for safety foods.

Action: The Individual/Entity is required to: operate and maintain the facility in accordance with the requirements of all applicable regulations, including S.C. Regs. 61-25; and, pay a civil penalty in the amount of five hundred fifty dollars **(\$550.00)**.

86) Order Type and Number: Consent Order 2016-206-04-004  
Order Date: September 26, 2016  
Individual/Entity: **Fastrack 1**  
Facility: Fastrack 1  
Location: 1014 Lamar Highway  
Darlington, SC 29540

Mailing Address: P.O. Box 214  
Darlington, SC 29540  
County: Darlington  
Previous Orders: None  
Permit Number: 16-206-01670  
Violations Cited: S.C. Code Ann. Regs. 61-25

Summary: Fastrack 1 (Individual/Entity) is a convenience store located in Darlington, South Carolina. The Department conducted inspections on July 29, 2015, and December 14, 2015. The Individual/Entity violated the South Carolina Retail Food Establishment Regulation as follows: failed to maintain proper holding temperatures of time/temperature control for safety foods.

Action: The Individual/Entity is required to: operate and maintain the facility in accordance with the requirements of all applicable regulations, including S.C. Regs. 61-25; and, pay a civil penalty in the amount of five hundred fifty dollars **(\$550.00)**.

87) Order Type and Number: Consent Order 2015-206-07-091  
Order Date: September 26, 2016  
Individual/Entity: **Mellow Mushroom**  
Facility: Mellow Mushroom  
Location: 19 Magnolia Road  
Charleston, SC 29407  
Mailing Address: Same  
County: Charleston  
Previous Orders: None  
Permit Number: 10-206-07852  
Violations Cited: S.C. Code Ann. Regs. 61-25

Summary: Mellow Mushroom (Individual/Entity) is a restaurant located in Charleston, South Carolina. The Department conducted inspections on September 23, 2015, October 9, 2015, October 19, 2015, and May 5, 2016. The Individual/Entity violated the South Carolina Retail Food Establishment Regulation as follows: failed to maintain proper holding temperatures of time/temperature control for safety foods.

Action: The Individual/Entity is required to: operate and maintain the facility in accordance with the requirements of all applicable regulations, including S.C. Regs. 61-25; and, pay a civil penalty in the amount of one thousand, two hundred dollars **(\$1,200.00)**.

---

\* Unless otherwise specified, "Previous Orders" as listed in this report include orders issued by Environmental Affairs Programs within the last five (5) years.